



PUBLIC NOTICE

Intertek Warns of Counterfeit Intertek Certification Document and Unauthorized use of ETL Certification Marks for Blowtherm Spa. Paint Spray Booth Lighting Fixtures

Published: July 27, 2016

The following is a notification from Intertek that the Authorization to Mark Certification Document is counterfeit and products in the market place are known to bear unauthorized ETL Certification Marks for the United States and Canada. The products have not been evaluated by Intertek in any way and it is not known if they comply with any safety requirements.

Product Description	<i>Paint Spray Area Lighting Fixtures for Use in Hazardous Locations</i> <i>Identified Models: LF-4-120, LF-4-277, LF-4-347, LF-6-120, LF-6-277, LF-6-347, 20013-1, and Extra L4-32-120</i> <i>Other models may also bear unauthorized marks as it has been confirmed that there are <u>no Lighting Fixtures ETL Certified for Blowtherm Spa.</u></i>
Manufacturer	<i>BLOWTHERM SPA</i>
Number of Units	<i>Unknown</i>
Identification	<i>ATM: See page 2 for full details</i> <i>Product: Unauthorized cETLus Mark and control number 3052925 identifying certified to UL std. 844 and CAN/CSA std. C22.2 No. 137 M91 - See photo on Page 2 for full details</i>
Reported Hazards	<i>Unknown - Not evaluated Intertek for use in Ordinary or Hazardous Locations</i>
Sold at	<i>Unknown</i>
What to do	<i>Immediately discontinue use and notify local authorities</i>

Counterfeit ATM and Product Nameplate

Intertek Testing Services NA Ltd.

AUTHORIZATION TO MARK

Date: November 20, 2003
This authorizes the manufacturer to apply the ETL mark to certified products when made in accordance with the accompanying descriptions and drawings under the conditions set forth in the Certification Agreement herein:

Applicant: Blowtherm Spa.
Via Guido Reni, 5,
35134 Padova, Italy
(39) 049 9300229

Manufacturer: Blowtherm Spa.
Via Borgo, Padova 89, 35012 Camposanpiero (PD)

Contact: Mr. Vincenzo Patron,
(39) 049 9300229

Reference Report No.: 3044064-7

Product Covered: Paint Spray Area Lighting Fixture.
For use in Hazardous Location


Description: Paint Spray Area Lighting Fixture.
For use in Hazardous location as Class 1 Division 2 Designation

Model: LF-4-120, LF-4-277, LF-4-347, LF-6-120,
LF-6-277, LF-6-347, 20013-1

Standard(s): UL 844 11th edition, CSA C22.2 No: 137 M81.

This procedure, with all revisions, etc., is the property of Intertek Testing Services and is intended solely for the guidance of the listee and the representative of Intertek Testing Services, and is not transferable.

COUNTERFEIT



Issued by: Intertek Testing Services NA Inc.
24 Groton Avenue
Cortland, NY 13045-2014 USA

Authorized by: _____ **Date:** _____
William Starr
Certification Manager

